



財團法人全國認證基金會
Taiwan Accreditation Foundation

Certificate of Accreditation

(Certificate No : L3718-231208)

This is to certify that

National Chung-Shan Institute of Science & Technology

EMP LAB

Building W47, No. 566, Ln. 134, Longyuan Rd., Longtan Dist., Taoyuan City 325, Taiwan
(R.O.C.)

is accredited in respect of laboratory

Accreditation Criteria : ISO/IEC 17025:2017 ; CNS 17025:2018

Accreditation Number : 3718

Originally Accredited : December 11, 2020

Effective Period : December 11, 2023 to December 10, 2026

Accredited Scope : Testing Field, see described in the Appendix



Scan to verify

Yi-Ling Chen

Yi-Ling Chen
President, Taiwan Accreditation Foundation
December 08, 2023

Accreditation Number : 3718

Laboratory Head : CHIEN, Wu-Long

17.99 Metrical Instrument
FIXED FACILITIES/TRANSPORTABLE SYSTEMS
E026 SHIELDING EFFECTIVENESS
MIL-STD-188-125-1, Appendix A
MIL-STD-188-125-2, Appendix A
IEEE Std 299

(On-site testing included)

Only for

Magnetic field shielding effectiveness: (10 kHz to 20 MHz)

Plane wave shielding effectiveness: (20 MHz to 1 GHz)

Dynamic Range: 46 dB at 10 kHz; 61 dB at 100 kHz; 80 dB at 1 MHz; 102 dB at 10 MHz;
133 dB at 100 MHz; 109 dB at 1 GHz

Test Frequency: 10 kHz to 1 GHz

Approval Signatory: WU, Kuo-Hsiang; CHIEN, Wu-Long

19.99 Electronic and Electric
FIXED FACILITIES/TRANSPORTABLE SYSTEMS
E002 Pulse Current Injection (PCI)
MIL-STD-188-125-1, Appendix B
MIL-STD-188-125-2, Appendix B

Only for

Standard PCI Source Waveforms:

1. Intrasite/Intracircuit power line POEs: Short pulse common mode, Short pulse wire-to-ground; Intermediate pulse common mode, Intermediate pulse wire-to-ground;
2. Intrasite/Intracircuit control/signal/data line POEs: Short pulse common mode, Short pulse wire-to-ground; Intermediate pulse common mode, Intermediate pulse wire-to-ground;
3. Intrasite/Intracircuit audio/data Line: Short pulse common mode, Short pulse wire-to-ground; Intermediate pulse common mode, Intermediate pulse wire-to-ground;

Approval Signatory: WU, Kuo-Hsiang; CHIEN, Wu-Long

19.99 Electronic and Electric
SUBSYSTEMS AND EQUIPMENT
E002 Radiated susceptibility-transient electromagnetic field
Laboratory developed methods -
EMP3-TE03 transient electromagnetic field test manual
Only self-defined pulsed field waveforms -
Maximum electromagnetic field strength: 50 ± 10 kV/m
Marx generator maximum output: 270 ± 30 kV
Marx generator Rise time: ≤ 20 ns
Marx generator FWHM: 150 ± 50 ns

Approval Signatory: WU, Kuo-Hsiang; CHIEN, Wu-Long

(Null below)

P2, total 2 pages

The Appendix forms an integral part of this Certificate, which shall be invalid when use without the Appendix

